

№ТТТ	Стр кВА	№Ф	I(A)			Uф(В) ток в самой удаленной точке от ТТТ			№ отб ПЫВ	Uф (В)			Uл (В)			время замера	
			A	B	C	A	B	C		A	B	C	A	B	C		
		1	65	76	93	229	236	222		A	B	C	A	B	C		
			2	76	53	50	227	242									227
			3	55	40	45	231	238									231
			сумма	196	169	188											
			P(кВт)	127,93													
4629	51,2	250	P(кВт)						230	240	224	405	402	405	18:00		
		1											A	B	C		
			2	46	40	42	219	217									221
			3	128	110	79	209	203									212
			сумма	174	150	121											
			P(кВт)	101,46													
4630	40,6	250	P(кВт)						227	230	227	391	394	399	18:15		
		1	144	101	113	226	232	234									
			2	20	87	84	230	223									218
			3														
			сумма	164	188	197											
			P(кВт)	127,92													
4631	51,2	250	P(кВт)						235	235	229	408	408	405	17:45		
		1	19	42	23												
			2	0	0	1											
			3	22	50	43											
			сумма	41	92	67											
			P(кВт)	45,20													
4612	18,1	250	P(кВт)						228	224	226	392	392	394	18:30		
		1	76	34	122	218	230	220									
			2	84	106	38	219	219									221
			3	11	47	23	228	225									220
			сумма	171	187	183											
			P(кВт)	125,51													
4613	39,8	315	P(кВт)						231	238	227	416	408	410	18:45		
		1	19	15	23												
			2	7	47	27											
			3	18	39	38											
			сумма	44	101	88											
			P(кВт)	52,81													
4666	21,1	250	P(кВт)						227	226	227	394	395	398	19:00		

